

SUMMARY OF TESTED FIRE RESISTANCE

We hereby declare that on July, 29th, 2020, in the facility **LGAI Technological Center, S.A. (APPLUS) Campus de la UAB. Ronda de la Font del Carme, s/n. 08193 Bellaterra - (Barcelona) (Spain)**, a fire door named **X644* (DOOR D)** has been tested according to **EN 1634-1:2014+A1:2018**. On November, 13th, 2020, the classification report **20/22763-1240-1** has been issued.

On the door has been incorporated the following hardware element:

Acoustic Alu^{*}

Manufactured by:

C.C.E. srl^{*}

Villa del Conte - Via dell'Artigianato, 16 - 35010 - (PD) - Italy

The door classified according to EN 13501-2:2016 as:

EI₁ 120

Category A

EI₂ 120

Category A

Signed on behalf of

LGAI Technological Center, S.A. (APPLUS)

Fire Laboratory Responsible



Digitally signed by
Albert Ger Castillo

CHEMOLLI FIRE

CEO

Eros Chemolli

CHEMOLLI s.a.s.
di Eros Chemolli & C.

Via Fitta, 1 - 38062 - Arco (TN)
C.F. , P.I./VAT IT02261290221

Date of issue: 21 December, 2020

* This information has been provided by Chemolli Fire.